



"Your Comfort Is Our Business"

**Burgeson's Heating and Air
Conditioning, Inc**
620 Tennessee Street
P.O. Box 7310
Redlands CA 92375

Invoice

Date	Number
10/17/2022	1348403

Bill To Address:
City Of Beaumont Elizabeth 550 E. 6th Street Beaumont, CA 92223

Work\Ship Address:
City Of Beaumont Elizabeth 550 E. 6th Street Beaumont, CA 92223

Agreement #	PO #	Terms	Due Date	Sales Rep	WO #
		Due Upon Receipt	10/17/2022	Anthony Orozco	275153

Item	Description	Amount
Diagnostic	Diagnostic	\$0.00
Repair	Service Repair install a new 60 amp rated 3 phase bolt-on circuit breaker -To supply and install a new 60 amp rated 3 phase bolt-on circuit breaker in existing electrical panel to supply power for existing exterior disconnect. (branch circuit wiring supplying disconnect is existing). An existing single pole 20-amp circuit will be relocated into nearby panel to allow space for the new 3 phase breaker in this panel (due to limited space in). Circuit wiring for this 20-amp circuit will be relocated in accessible crawl space using electrical conduit. All electrical connections will be tested for proper voltage. (All work includes a 1-year labor and Materials warranty) - hold all day Technician Anthony Installed a 60amp 3pole breaker and relocated a 20amp circuit to another panel to make room for the 60amp 3 pole breaker. For the 60amp 3pole breaker there was an existing 30amp 2pole breaker I removed that and added the 60amp, on the 30amp breaker the wiring was ran for a 2-pole breaker with 2 hots and a neutral, the new AC unit that was being installed needs a 3phase disconnect so I used the neutral as another phase for the disconnect. I had removed a circuit from where the 60amp breaker was being installed to make room for the new breaker. And had to go under the building through the crawl space to relocate the 20amp circuit to another nearby panel. The existing MC cable wasn't long enough so I had to add a junction box and splice in there and run another 5ft of MC cable to another junction box and from there was an existing spare 1/2" EMT going up into the panel, so I ran some #12 THHN from the junction box through the EMT up into the panel and added it do a existing spare breaker that was labeled #19 on the panel. After breakers were installed, I	\$2,275.00

Your Comfort Is Our Business.

Sales Tax	\$0.00
Total	\$2,275.00
Balance Due	\$2,275.00

Phone #	Fax #	E-mail
909-792-2222	909-792-2149	



"Your Comfort Is Our Business"

**Burgeson's Heating and Air
Conditioning, Inc**
620 Tennessee Street
P.O. Box 7310
Redlands CA 92375

Invoice

Date	Number
10/17/2022	1348403

Bill To Address:
City Of Beaumont Elizabeth 550 E. 6th Street Beaumont, CA 92223

Work\Ship Address:
City Of Beaumont Elizabeth 550 E. 6th Street Beaumont, CA 92223

Agreement #	PO #	Terms	Due Date	Sales Rep	WO #
		Due Upon Receipt	10/17/2022	Anthony Orozco	275153

Item	Description	Amount
	tested the voltage and was receiving 120volts with no issues. We thank you for your business. By Tasha on 10/18/2022 at 8:09:44 AM: Brad supplied braker	

Your Comfort Is Our Business.

Sales Tax	\$0.00
Total	\$2,275.00
Balance Due	\$2,275.00

Phone #	Fax #	E-mail
909-792-2222	909-792-2149	