



Staff Report

TO: City Council

FROM: Thaxton Van Belle, Director of Water Reclamation
Sunshine Sanchez, Management Analyst

DATE July 15, 2025

SUBJECT: Follow-Up Report No. 7 Local State of Emergency Sewer Mainline Failure
Emergency Repairs in Fairway Canyon

Description The City is retroactively pursuing environmental permits due to the local emergency cause by the sewer mainline failure in Fairway Canyon. A resolution to re-ratify the declared state of local emergency is needed.

Background and Analysis:

On March 3, 2025, City staff were notified of a major sewer mainline failure in the Fairway Canyon community caused by slope erosion behind Hogan Drive homes. The incident led to a manhole collapse and subsequent 15-inch sewer mainline failure, resulting in a raw sewage spill and the need for emergency response measures.

On March 4, 2025, City Council adopted a Resolution titled, "A Resolution Of The City Council Of The City Of Beaumont Declaring A Local Emergency And Authorizing The City Manager To Take Necessary Action", which authorized emergency expenditures in an amount not to exceed \$500,000, directed staff to provide ongoing reports at each subsequent City Council meeting under California Public Contract Code Section 22050, and authorized the City Manager to take all necessary actions to mitigate further damage and ensure public health and safety.

On March 18, 2025, staff brought a follow-up status report regarding the emergency repairs in Fairway Canyon. No action was taken, but updated pictures were provided, along with an estimated amount of \$21,000 that has been expended.

On April 1, 2025, staff brought a follow-up status report regarding the emergency repairs in Fairway Canyon. The full financial impact to date was \$432,101 including requisitions added and costs on bypass pumping, equipment, and fuel. Staff were approved for an additional \$500,000 to increase the total allocation to \$1,000,000 to cover the costs for repairs.

On April 15, 2025, staff provided a follow-up regarding the emergency repairs in Fairway Canyon, which included construction progress updates with pictures and expenditures paid to date.

On May 6, 2025, staff provided an update on construction activity with pictures of completed items.

On June 3, 2025, the City Council re-ratified the Local Emergency Declaration through a second resolution.

On June 17, 2025, staff provided an update to the City Council that, on the recommendation of legal counsel, the emergency status remains open while the City pursues environmental permits retroactively.

Staff is currently coordinating with applicable agencies for permitting. The costs are displayed in the following table:

| Expenditures as of June 30, 2025 | Encumbered | Amount Spent |
|-------------------------------------|----------------------|----------------------|
| Fuel for bypass pumps | \$ 2,346.00 | \$ 2,972.00 |
| Miscellaneous equipment | \$ 1,294.00 | \$ 1,168.00 |
| Electrical | \$ 8,627.00 | \$ 8,627.00 |
| Charles King (Bypass pumps) | \$ 40,000.00 | \$ 23,552.00 |
| Weaver Grading | \$ 389,500.00 | \$ 354,500.00 |
| Legal Services | \$ - | \$ 34,206.00 |
| State Water Resources Control Board | | \$ 4,212.00 |
| Total | \$ 441,767.00 | \$ 429,237.00 |

Fiscal Impact:

All emergency-related costs were paid from the Wastewater contingency account. Although this account has exceeded its budget, Wastewater Fund revenues are tracking higher than anticipated, therefore, no reserve funds will be required. Overall, the Wastewater Fund remains within its total appropriated budget.

The estimated cost to prepare this staff report is \$150.

Recommended Action:

Waive the full reading and adopt by title only, "A Resolution Of The City Council Of The City Of Beaumont Extending The Declaration of A Local Emergency and

Authorizing The City Manager To Take Necessary Action”, and
Direct staff to return at the next Council meeting regarding the status and
requirements of applicable environmental permits.

Attachments:

- A. Resolution Extension