APPROVAL

City of Beaumont Fire Department
Office of the Fire Marshal

By: Clay Shepard

Digitally signed by Clay Shepard
DN: C=US, E=cshepard@beaumontca.gov, CN=Clay Shepard
Reason: I am approving this document
Date: 2024.01.12 10:29:08-08'00'

CShepard
05/22/2025 6:40:41 AM

The approval of plans and specifications does not permit the violation, deletion, omission or faulty installation of any requirements of Title 24 or any Local Ordinances. Construction shall remain accessible and exposed for inspection purposes until approved by the Fire Department.

PLAN2025-0186 & FP2025-0154

Permanent Fencing
Temporary Fencing
P33 Fire Extinguisher
Pedestrian Gate
Emergency Exit
V7 Vehicular Gate
Fire Access
Temporary Gate
24' Fire Access Gate
Existing Gate
Security acting as Crowd Manager
Security with other duties

Existing Light Pole
1 Number of Bulbs
Fire Hydrant
Generator
Spider Box
6 AWG wire 50 AMP

GATES TO REMAIN LOCKED IN OPEN POSITION

P15	P22
P15	P23
P17	P27
P18	P28
P19	P29

Concessionares/Exhibitors - Non Food
Concessionares - Food
EZ-up Canopy - Non Vendor
Beer Trailer
Temporary Light Tower
Light Direction
Trash Bins
Potable Water holding tank

Field 2
SF: 56,454
Occupancy Load: 8,065
Required Egress: 41'
Actual Egress: 54'
3 Exits

Field 3
SF: 58,851
Occupancy Load: 8,407
Required Egress: 43'
Actual Egress: 66'
4 Exits

Field 4
SF: 20,519
Occupancy Load: 2,932
Required Egress: 15'
Actual Egress: 34'
3 Exits

MEADOW
SF: 104,845
Occupancy Load: 14,977
Required Egress: 73'
Actual Egress: 76'
7 Exits

FIELD 7
SF: 47,188
Occupancy Load: 6,742
Required Egress: 34'
Actual Egress: 66'
5 Exits

Applicable Codes
2022 California Building Code (CBC)
2022 California Plumbing Code (CPC);
2022 California Mechanical Code (CMC);
2022 California Electric Code (CEC);
2022 California Existing Building Code (CEBC);
2022 California Energy Code;
2022 California Green Building Standards (CGBSC);
and The City of Beaumont Local Ordinances.

Field 1 Fence - directly opposite AA

EXIT
ENTRANCE
ENTRANCE

FIELD 4
FIELD 3
FIELD 2
FIELD 7
MEADOW

FIRE LANE

P1 65' BLOWOUT FENCE
P2 8' EMERGENCY EXIT
P3 8' EMERGENCY EXIT
P4 8' EMERGENCY EXIT
P5 135' BLOWOUT FENCE
P6 10' EMERGENCY EXIT
P7 8' EMERGENCY EXIT
P8 110' BLOWOUT FENCE
P9 6' EXIT
P10 24' EMERGENCY EXIT
P11 24' EMERGENCY EXIT
P12 10' EMERGENCY EXIT
P13 24' EMERGENCY EXIT
P14 24' EMERGENCY EXIT
P15 10'
P16 20'
P17
P18
P19
P20 20' EXIT
P21 24' EMERGNECY EXIT
P22 10'
P23
P24 4'
P25 6'
P26 24' EXIT
P27 20'
P28 16'
P29
P30 52" BLOWOUT GATE
P31 24' EMERGENCY EXIT
P32 8' EMERGENCY EXIT

V1 24' FIRE ACCESS
V2 24' FIRE ACCESS
V3 24' FIRE ACCESS
V4 24' FIRE ACCESS
V5 24' FIRE ACCESS
V6 24' FIRE ACCESS
V7 24' FIRE ACCESS
V8 24' FIRE ACCESS
V9 24' FIRE ACCESS
V10 24' FIRE ACCESS
V11 24' FIRE ACCESS
V12 24' FIRE ACCESS

Existing Dog Park will serve as an Area of Refuge

NOTE: Vendors will utilize 10x10 EZ ups and have been notified that 10x10 EZ will be available for rent if they arrive with EZ ups that are not i increments of 10 ft.

NOTE: Fire Extinguishers are sizes 1A10BC and 2A10BC. 1A10BC will be spaced every 35 ft compared to 2A10BC spaced every 70ft.

NOTE: SECURITY is scheduled to be onsite every day 1 hour prior to opening

NOTE: Field 2's row seating will be secured to each other in a minimum grouping of 3 chairs.

Aisles will be marked on the field for maintaining egress pathways between sections of chairs.

NOTE: All ADA accessible walkways have no more than 2% cross slope and 5% walking slope as per CBC 11B-403.3

NOTE: FIELD LIGHTS will be utilized on all fields

NOTE: All trees within the fire apparatus lanes will be trimmed to provide 13'6" clearance prior to the start of the festival

NOTE: NO SMOKING signage and NFPA 704 placards will be placed on all generators. GENERATORS will be separated from public access.

OAK VALLEY PKWY
OAK VALLEY PKWY
OAK VALLEY PKWY